

ARHAM QUALITY CONTROL LABORATORY

14-B, Sneh Nagar, 204-II Floor, Sapna Sangeeta Road, Near Lotus Electronics, Indore Ph.: 0731-4247455, 2466374
E-mail : aqclabs@gmail.com, web: www.aqclabs.com



CA. No.: B2 272

Approved by : Govt. of India under "AGMARK" | An ISO 9001:2015 Certified Laboratory

TEST REPORT

Page 1 of 1

Issued from :	Arham Quality Control Laboratory (AQC Labs)		
Issued to :	M/S The Millennium School, Halka No. 13, Nayata Mundla, AB Road Bypass, Opp. Silver Springs Township, Indore(MP)		CoA ID :
			AQC-Labs/10926/2019-20
			Issue Date:
			16/01/2020
		Sample ID:	L-10926

Name of Sample: Bore Well Water		Sample Particulars	
Sample Received Date: 08/01/2020			
Quantity:	2 litre		
Batch No.:		Sealed / Unsealed:	Unsealed
Other Details:	Date of Mfg.:	Date of Expiry:	
Description:	Bore Well Water		

(A) Table-1					
S.No.	Characteristic	Units	Specification	Result	Test Method
Chemical Parameters					
1	pH Value	-	6.5-8.5	7.91	IS 3025 Part 11
2	Odour	-	Agreeable	Agreeable	IS 3025 Part 5
3	Total Dissolved Solids (as TDS)	mg/l	Max 500	207.0	IS 3025 Part 16
4	Total Hardness (as CaCO ₃)	mg/l	Max 200	164.34	IS 3025 Part 21
5	Chloride (as Cl)	mg/l	Max 250	32.60	IS 3025 Part 32
6	Calcium (as Ca)	mg/l	Max 75	28.56	IS 3025 Part 40
7	Magnesium (as Mg)	mg/l	Max 30	22.88	IS 3025 Part 46
8	Total Alkalinity (as CaCO ₃)	mg/l	Max 200	128.52	IS 3025 Part 23

(B) Table-2					
Microbiological Parameters					
2	E.coli	MPN/100 ml	Shall not be detectable In any 100 ml of water	Absent	IS 1622
3	Coliform	MPN/100 ml	Shall not be detectable in any 100 ml of water	Absent	IS 1622

S. K.

Arham Quality Control Laboratory
LABS
Authorized Signatory

- Sample (S) drawn and submitted by the customer, unless otherwise stated.
- This certificate refers only to the particular item submitted.
- The result listed refer only to the tested sample and applicable parameters.
- The report will not be reproduced wholly or in-part without special permission in writing.
- The liability of the laboratory is limited to the invoiced amount.
- The sample will be destroyed after two weeks from the date of issue of certificate, unless perishable item.
- Test method not mentioned by the customer, unless otherwise stated.
- In case of any dispute Indore jurisdiction shall be referred.