

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 4213

Date: 10/10/2024

It is certified that an inspection team headed by A.C.M.O./Deputy C.M.O. Gautam Budh Nagar. **The Millennium School, SS-01, Sector-119, Noida, G.B Nagar.** on dated 09-10-2024 and found that **The Millennium School** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

The above valid for a period of 1 Year.

Signature with Seal:-


Chief Medical Officer

Name:-

Dr. Sunil Kumar Sharma

Designation:-

Chief Medical Officer

To

The Principal,
The Millennium School
SS-01, Sector-119, Noida
Gautam Budh Nagar.





DeltaPure Technologies (I) Pvt. Ltd.
 Plot No. 14/5, Jainco Complex, Mathura Road,
 Sec.-31, Faridabad, Haryana - 121003
 Next to Mewla Maharajpur Metro Station
 CIN : U29259DL1996PTC081797
 Tel : 0129-4885210-11-12
 Email : info@deltapuretech.com



Water Test Report

Test Report Ref. No 2425/1904/1

Sample Collected on: 30th January, 2025

Sample Collected in: PET 500 ml bottle

Sample Collected by: Mr. Sunil Kumar

Sample Collected from: - The Millennium School
 SS-1, Sector-119, Noida, U.P

S No	Parameter	Result	Desired Limit	Permissible Limit
A	General			
1	Taste	Agreeable	Agreeable	Agreeable
2	Odor	Unobjectionable	Unobjectionable	Unobjectionable
3	Color, in Hazen Unit	Acceptable	5	25
B	Physical			
4	Turbidity NTU	<1 NTU	5 NTU	10 NTU
5	Total Dissolved Solids mg/l	80	500	2000
6	Conductivity micros at 25°C	140	N.S.	N.S.
7	pH	7.3	6.5 - 8.5	No relaxation
C	Chemical			
8	Total Alkalinity (as CaCO ₃), mg/l	12	200	600
9	Total Chlorides (as Cl), mg/l	11	250	1000
10	Residential Free Chlorine ppm	NIL	0.2(min.)	-----
11	Total Hardness as CaCO ₃	26	300	600
12	Silica -ppm	NIL	1.0	50.0
13	Dissolved Iron (as Fe), mg/l	0.02	0.3	1.0
D	Bacterial			
14	E. Coli	Absent	Negative	No relaxation
15	Coliform (MPN/100 ml)	NIL	10	No relaxation

Remarks The no. of parameters tested is 15 only. The results indicate that the Quality of water considered being desired limits for drinking as per IS: 10500, in regard to the parameters tested. The report is issued subject to the terms & conditions.

Sample Tested by:

Pintu Kumar
 (Lab Assistant)
 Pintu Kumar

Sample Tested on: - 04-02-2025

Checked By:

Mahender Singh
 (Q.C. Head)
 Mahender Singh



Date: 4th February, 2025



Shirha