

o/c



The  
**Millennium**<sup>TM</sup>  
School  
Noida Sec 119

(Affiliation No. 2133481, School Code 61357)

Date: 20.10.2025

The Chief Medical Officer Sector 39 Noida  
Gautam Budh Nagar  
Uttar Pradesh

Subject: Health And Sanitation Certificate

Dear Sir,


This is in reference to issuing of Health & Sanitation Certificate for the Millennium School, Sector 119, and Noida.

We would like to inform that competent authority that we provide safe RO drinking water along with maintaining of Hygienic and sanitation condition across the School premises as prescribed by the Central/state/U.T Government and CBSE guidelines.

It is therefore requested to kindly issue the certificate for Safe Drinking Water and Sanitary condition Certificate for our School.


Thanking you in anticipation

For THE MILLENNIUM SCHOOL


  
Authorised Signatory



PRINCIPAL  
THE MILLENNIUM SCHOOL  
SEC 119, NOIDA

  
23/10/25

DeltaPure Technologies (I) Pvt. Ltd.  
 Plot No. 14/5, Jainco Complex, Mathura Road,  
 Sec.-31, Faridabad, Haryana - 121003  
 Next to Mewla Maharajpur Metro Station  
 CIN : U29259DL1996PTC081797  
 Tel : 0129-4885210-11-12  
 Email : info@deltapuretech.com



### Water Test Report

Test Report Ref. No 25-26/26316/1  
 Sample Collected on: 11<sup>th</sup> March, 2026  
 Sample Collected in: PET 500 ml bottle

Sample Collected by: Mr. Sunil Kumar  
 Sample Collected from: - The Millennium School  
 SS-1, Sector-119, Noida, U.P


S.No.	Parameter	Result	Desired Limit	Permissible Limit
<b>A General</b>				
1	Taste	Agreeable	Agreeable	Agreeable
2	Odor	Unobjectionable	Unobjectionable	Unobjectionable
3	Color, (Pt-Co) Unit	Acceptable	5	25
<b>B Physical</b>				
4	Turbidity NTU	<1 NTU	5 NTU	10 NTU
5	Total Dissolved Solids mg/l	85	500	2000
6	Conductivity (µmhos/cm) at 25°C	148	N.S.	N.S.
7	pH	7.2	6.5 - 8.5	No relaxation
<b>C Chemical</b>				
8	Total Alkalinity (as CaCO <sub>3</sub> ) mg/l	10	200	600
9	Total Chlorides (as Cl <sup>-</sup> ) mg/l	12	250	1000
10	Residential Free Chlorine ppm	NIL	0.2(min)	-----
11	Total Hardness as CaCO <sub>3</sub>	29	300	600
12	Silica mg	NIL	1.0	50.0
13	Dissolved Iron (as Fe) mg/l	0.01	0.3	1.0
<b>D Bacterial</b>				
14	E-Coli	Absent	Negative	No relaxation
15	Coliform (at 20°C)	NIL	10	No relaxation

Remarks: The no. of parameters tested is 15 only. The results indicate that the Quality of water considered being desired limits for drinking as per IS: 10500. in regard to the parameters tested. The report is issued subject to the terms & conditions

Sample Tested by:  
*Prem Kumar*  
 (Lab. Assistant)  
 Prem kumar

Sample Tested on:-16<sup>th</sup> March, 2026

Checked By:  
*Mahender Singh*  
 (Q.C. Head)  
 Mahender Singh



Date: 16<sup>th</sup>, March, 2026

*Shikha*  
 PRINCIPAL  
 THE MILLENNIUM SCHOOL  
 SEC 119, NOIDA

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY  
CONDITION CERTIFICATE**


No. 4213

Date: 10/10/2024

It is certified that an inspection team headed by A.C.M.O./Deputy C.M.O. Gautam Budh Nagar. **The Millennium School, SS-01, Sector-119, Noida, G.B Nagar.** on dated 09-10-2024 and found that **The Millennium School** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

The above valid for a period of 1 Year.

Signature with Seal:-

  
**Chief Medical Officer**

Name:-


**Gautam Budh Nagar**  
Dr. Sunil Kumar Sharma

Designation:-

Chief Medical Officer

To

The Principal,  
The Millennium School  
SS-01, Sector-119, Noida  
Gautam Budh Nagar.



PRINCIPAL  
THE MILLENNIUM SCHOOL  
SEC 119, NOIDA