



ਦਫ਼ਤਰ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ
ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ
ਉਪ ਮੰਡਲ ਨੰ: 3, ਪਟਿਆਲਾ



E-Mail:- sdewss3patiala@gmail.com

To:

The Principal,
The Millennium School
VPO Nandpur Kesho Patiala.

Memo No. 547


Date: 12-05-2026


Subject Water Sanitation Certificate.

The inspection of The Millennium School VPO Nandpur Kesho Patiala was conducted on 06.05.2026 by our Junior Engineer Sh. Amit Kumar Our Junior Engineer found that the air circulation is satisfactory and it is air cooled. The Number of urinals & latrines for males and females are adequate, neat and clean. The source of water supply is through submersible pump.

Note: This Certificate is valid for one year (From Date of Issue)

DA:- Water Sample Test Report of Above mentioned School.


SubDivisional Engineer,

 W/S & Sanitation, Sub. Div. No. 3,
Patiala.

**TRADE WASTE AND EFFLUENTS RESEARCH UNIT (REGIONAL LAB)
PATIALA**

Room No. 301, 2nd Floor, Water Supply & Sanitation Department, Head Office, Nabha Road, Patiala
researchunitpatiala@yahoo.in

To,

The millennium School, Nandpur kesho
Nandpur kesho, Sirhind Road, Patiala.

No.: TWERU/2627/00070 Dated : 30/04/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 133 Dated: 27/04/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 27/04/2026. It is request to fill the attached feedback form and send it back to Trade Waste and Effluents Research Unit (Regional Lab) Patiala

D/A : Test Report



**Authorized Signatory
For, Trade Waste and Effluents Research Unit
(Regional Lab) Patiala**

TRADE WASTE AND EFFLUENTS RESEARCH UNIT (REGIONAL LAB) PATIALA

Room No. 301, 2nd Floor, Water Supply & Sanitation Department, Head Office, Nabha Road, Patiala
researchunitpatiala@yahoo.in



TC-14242

TEST REPORT						
Name & Address of Customer : The millennium School, Nandpur kesho Nandpur kesho, Sirhind Road, Patiala.			Customer Reference No.		No : 133 Dated : 27/04/2026	
			Sample Submitted by		Mukesh kumar	
			Date of Sample Receipt		27/04/2026	
			Analysis Starting Date		27/04/2026	
			Analysis completion Date		30/04/2026	
Discipline : Chemical Testing			Group: Water			
ULR No.:	TC14242260000145F		Sample Type :		Water	
Test Report No.:	TWERU/2627/00070		Date of Issue :		30/04/2026	
Registration no.:	TWERU/REG2627/00279		Condition of Sample :		Unsealed	
Collection Point:	Private Submersible		Quantity/Type of Bottle:		2000 ml / Plastic Bottles	
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :		Submersible at The Millennium School, Nandpur kesho, Sirhind Road, Patiala. / 420 ft	
Village :	Not Mentioned		Habitation :		Not Mentioned	
Block:	Not Mentioned		District :		Patiala	
Latitude :	Not Mentioned		Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.30	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	TDS	120	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
3	Turbidity	0.90	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
4	T. Alkalinity(CaCO3)	40	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
5	T. Hardness(CaCO3)	76	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
6	Calcium(Ca)	14	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
7	Magnesium(Mg)	10	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
8	Fluoride(F)	0.35	1.0	1.5	mg/l	APHA 24th Ed.2023, Method 4110
9	Chloride(Cl)	9	250	1000	mg/l	APHA 24th Ed.2023, Method 4110
10	Nitrate(NO3)	2	45	No Relaxation	mg/l	APHA 24th Ed.2023, Method 4110
11	Sulphate(SO4)	6	200	400	mg/l	APHA 24th Ed.2023, Method 4110
12	Iron	BDL(0.2)	1	No Relaxation	mg/l	APHA 3111-B (23rd Ed. 2017) by AAS
13	Manganese	BDL(0.1)	0.1	0.3	mg/l	APHA 3111-B (23rd Ed. 2017) by AAS

Continue on next page...

Reviewed and Approved By

Brij Bhushan

Sh. Brij Bhushan
Quality Manager
Authorized Signatory
For, Trade Waste and Effluents Research Unit
(Regional Lab) Patiala

**TRADE WASTE AND EFFLUENTS RESEARCH UNIT (REGIONAL LAB)
PATIALA**

Room No. 301, 2nd Floor, Water Supply & Sanitation Department, Head Office, Nabha Road, Patiala
researchunitpatiala@yahoo.in



14	Zinc	BDL(0.2)	5	15	mg/l	APHA 3111-B (23rd Ed. 2017) by AAS
15	Arsenic(As)	BDL(0.005)	0.01	No Relaxation	mg/l	APHA 3114 (23rd Ed. 2017) by HVG-AAS
16	Residual Chlorine(RC)	BDL(0.17)	0.2	1	mg/l	IS-3025 (Part-26) by Iodometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

**Sh. Brij Bhushan
Quality Manager
Authorized Signatory
For, Trade Waste and Effluents Research Unit
(Regional Lab) Patiala**

----- End of the Test Report -----